


#### **Motion Detector ZN1IO-DETEC-X**


# **Motion Sensor**

## **Technical Documentation**

#### **Description:**


- 1. LED indicating operation (red).
- 2. Superficial enclosure for motion sensor.
- 3. Connection terminal.
- 4. Micro-switch: On/Off LED indicating operation.







| ON | ] |                |                          |                         |
|----|---|----------------|--------------------------|-------------------------|
|    |   | Micro-switch   | ON                       | OFF                     |
|    |   | 1              | No Function              |                         |
|    |   | 2              |                          |                         |
|    |   | 3 - LED ON/OFF | Motion detection LED OFF | Motion detection LED ON |

### Dimensions (mm.) and positioning:







## **Detection Area:**

| Detection Area |                |                |  |  |  |  |
|----------------|----------------|----------------|--|--|--|--|
| Ceiling height | Distance Axe X | Distance Axe Y |  |  |  |  |
| 2.7m           | 6.67m          | 5.59m          |  |  |  |  |
| 5m             | 12.35m         | 10.36m         |  |  |  |  |
|                | Ë,             |                |  |  |  |  |
| S.7            |                |                |  |  |  |  |
| 5°.7           |                | 12m.           |  |  |  |  |


5,59 10,36

## **Connection Scheme:**


Option 1: 1 motion sensor

The desired Zennio device input is connected to the sensor terminal marked with the letter I.

In closing, connect the Zennio device common (any terminal marked with the letter "C") to the sensor terminal marked with the letter C.



account the axes X-Y position for optimizing the detection





## ZN1IO-DETEC-X

T

## **Motion Sensor**

### **Technical Documentation**


**Option 2**: 2 motion sensors connected in parallel (connected to the same input).

The desired Zennio device input is connected to sensor terminal number 1 which is marked with the letter **I**.

Next step consists in connecting the Zennio device common (any terminal marked with letter "C") to the sensor terminal number 1 marked with the letter **C**.

Do the same operation again with sensor 2, using the same Zennio device input.

Maximum 2 sensors in parallel.



| GENERAL SPECIFICATIONS            |   |  |  |  |
|-----------------------------------|---|--|--|--|
| Concept                           | Description   |  |  |  |
| Device type                       | Electric Operation Control Device   |  |  |  |
| Consumption (detecting status)    | 1mA   |  |  |  |
| Consumption (stand-by)            | 15µA  |  |  |  |
| External power supply             | 3.3V or 5V through the common terminal  |  |  |  |
| Ambient temperature               | 0°C to +55°C  |  |  |  |
| Storage temperature               | -20°C to +70°C  |  |  |  |
| Ambient humidity (relative)       | 30 to 85% RH (no condensation)  |  |  |  |
| Storage humidity (relative)       | 30 to 85% RH (no condensation)  |  |  |  |
| Protection class                  | IP 20, clean environment  |  |  |  |
| Assembly                          | False ceiling recommended. Avoid its assembly near light spots or other heat sources.                     |  |  |  |
| Performance indicator             | When detecting presence, the LED flashes. Cancellable function with the corresponding micro switch        |  |  |  |
| PCB CTI index                     | 175 V   |  |  |  |
| Enclosure                         | PC+ABS FR V0 halogen free   |  |  |  |
| Weight                            | 25 g.   |  |  |  |
| Connection type                   | Screw terminal clamp  |  |  |  |
| Max cable length                  | 30 meters (Zennio device input specification. Look up compatible devices)                                 |  |  |  |
| Cable section                     | 0.15mm <sup>2</sup> to 1 mm <sup>2</sup> (Zennio device inputs specification. Look up compatible devices) |  |  |  |
| Max number of sensors in parallel | 2   |  |  |  |
| Detection angle axe X             | 51°   |  |  |  |
| Detection angle axe Y             | 46°   |  |  |  |

#### SAFETY INSTRUCTIONS

- Do not connect to the main voltage (230 V) or any other external voltages. Connect only to proper Zennio device inputs. Connecting an external voltage might put all the KNX system into risk.
- Installation should only be performed by qualified electricians following applicable regulations on preventing accidents, as required by law.
- Keep away from water. If product comes into contact with water or other liquid, unplug immediately.